

TEST REPORT N° LYC-07-2199-24

Flame persistence test according to NF P 92-504

Test carried out as request of : **TREVIRA GmbH – Max –Fisher-Str.11- D-86399 BOBINGEN**

Material: **TREVIRA CS®**

Reference of the sample: **CETUS**
From: VAN CLEWE SUN PROTECTION GMBH

Application number: **070832-1**

Date of samples reception: **11/05/2007**

Samples	Duration of inflammation after removal of the flame (s)									
	1	2	3	4	5	6	7	8	9	10
WARP (L)										
<i>Front Side</i>	0	0	0	0	0	0	0	0	0	0
<i>Back Side</i>	0	0	0	0	0	0	0	0	0	0
WEFT (Q)										
<i>Front Side</i>	0	0	0	0	0	0	0	0	0	0
<i>Back Side</i>	0	0	0	0	0	0	0	0	0	0


Formation of no flaming drops : **yes**
Spread of flame : **no**

Formation of flaming drops: **no**

Results obtained should give the following classification:

M 1

The official and definitive classification can be delivered only after complete tests carried out according to the 21th November 2002 regulation.



Responsible for the test
Jean-Marc ORAISON

This report shall only be reproduced in full. It includes 1 pages and 0 annex (es).

GENERAL CONDITIONS (EXTRACT) : Art 2.1: The request for tests and associated services whose realization is entrusted to the laboratories INSTITUT FRANÇAIS DU TEXTILE ET DE L'HABILLEMENT, is the subject of request written by the customer to which are required to join the samples to test. This request indicates with precision the identity and the address of the applicant, the number, the nature, the denomination and the references of the samples, the object of required work. ART 2.3.1: The requests are classified by order of reception and the tests included in the same order. In the event of urgency or of particular contractual agreement, the tests can be carried out in priority. In this case, the Institute can mark up the price mentioned in the catalogue of the tests under conditions suggested to the customer and accepted. ART 2.2.3: On request of the customer, a control sample subjected to tests can be given to him, provided with the identification of the INSTITUT FRANÇAIS DU TEXTILE ET DE L'HABILLEMENT. ART 5.2: The INSTITUT FRANÇAIS DU TEXTILE ET DE L'HABILLEMENT can not be held responsible for various interpretations and the use which can be made reports/ratios of tests, reports/ratios of interpretations, comments, opinion and observations. ART VI: The use and/or the reference to name INSTITUT FRANÇAIS DU TEXTILE ET DE L'HABILLEMENT are subordinated to the written authorization of Management of the Institute. ART 2.2.4: At the end of the tests, the residual part not used samples is preserved in accordance with the procedures of the Quality management system of the site of the Institute where the tests are carried out. ART 4.2.2: Except particular stipulation, the invoices and requests for instalment are payable at the Institute at the address of realization of the tests and the associated services, the cash by transfer, by cheque, at reception of the invoice.

Direction Régionale Rhône-Alpes PACA
Avenue Guy de Collongue ● 69134 ECULLY CEDEX
Tél : (+33) (0)4 72 86 16 00 ● Fax : (+33) (0)4 78 43 39 66
SIRET 433 430 832 00017

Results of this report are only valid for specimens submitted to testing at IFTH. The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.